



# Certificate of Compliance

**Certificate:** 70029878

**Master Contract:** 151933

**Project:** 70029878

**Date Issued:** September 24, 2015

**Issued to:** Killark Electric Manufacturing Co.

3940 Dr. Martin Luther King Dr.  
St. Louis, MO 63113  
USA  
Attention: Brian Pegg

*The products listed below are eligible to bear the CSA Mark shown*



*Siros Ghanbarzadeh*

**Issued by:** Siros Ghanbarzadeh

## **PRODUCTS**

**CLASS 4418 02** - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Close-up Plugs, Cat. Nos. CUP-250, CUP-375, CUP-1 through CUP-0, conduit sizes 1/4 in., 3/8 in., and 1/2 in. through 4 inch,

for use in hazardous locations Class I, Groups A, B, C, D; Class II, Groups E, F, G; Class III.

## **APPLICABLE REQUIREMENTS**

The following standards were used in the evaluation of the products covered under this Certificate:

CSA Standard. C22.2 No. 0-10-M1985 (reaffirmed 2015) - General Requirements - Canadian Electrical Code, Part II

CSA Standard C22.2 No. 30-M1986 (reaffirmed 2012) - Explosion-Proof Enclosures for Use in Class I, Hazardous Locations

CSA Standard C22.2 No. 25-1966 (reaffirmed 2014) - Enclosure for use in Class II, Groups E, F and G; Hazardous Locations



**Certificate:** 70029878

**Master Contract:** 151933

**Project:** 70029878

**Date Issued:** September 24, 2015

---

CSA Standard C22.2 No. 45-M1981 (reaffirmed 2003) - Rigid Metal Conduit

CSA Standard C22.2 No. 0.5-M1982 (reaffirmed 2012) - Threaded Conduit Entries

ANSI/UL 1203 5th Edition - Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified)  
Locations

### **MARKINGS**

The following markings are stamped into the conduit fittings:

- Submitter's name or trade Mark;
- Catalogue number or Type Designation;
- Hazardous Locations Designation;
- CSA Monogram