

# Certificate of Compliance

Certificate Number **20080609-E197061**  
Report Reference **E197061, 2008 June 4**  
Issue Date **2008 June 9**

Page 1 of 1



*Issued to:* **WEIDMUELLER INTERFACE GMBH & CO KG**  
Klingenbergstrasse 16  
32758 Detmold, Germany

*This is to certify that  
representative samples of*

## **AUXILIARY DEVICES**

Enclosure Series, Model:  
Klippon STB, followed by 1 SS or 1.1 SS

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*

UL 508 17th Edition, dated 1999-01-28 - Industrial Control Equipment  
CSA 22.2 No. 14-05, approved 2006-03 - Industrial Control Equipment

*Additional Information:*


Ratings:

Type Rating: 4 / 4X

Ambient Temperature range: -50°C to +135°C

Tightening Torque (cover screws): 22.1 lb-in, (2.5 Nm)

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:  
**Bjoern Aschemann, Project Engineer**  
Underwriters Laboratories Inc.

Reviewed by:  
**Guido Bitter, Senior Project Engineer**  
Underwriters Laboratories Inc.