



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx ULD 14.0005U Issue No: 2 Certificate history:  
Status: **Current** Page 1 of 4 Issue No. 2 (2016-11-22)  
Date of Issue: **2016-11-22** Issue No. 1 (2015-08-11)  
Issue No. 0 (2014-10-16)

Applicant: **Weidmüller Interface GmbH & Co. KG**  
Klingenbergstrasse 16  
32758 Detmold  
**Germany**

Equipment: **Feed through and protective conductor terminal blocks, types WDU and WPE**

Optional accessory: *Type WQV screw in cross-connectors, type ZQV plug-in cross-connectors, type LS2.8 shield bus, type WEW end brackets, type WTW partitions and type WAP end plates for fixing on mounting rails*

Type of Protection: **Increased Safety "eb"**

Marking: Ex eb IIC

Approved for issue on behalf of the IECEx  
Certification Body:

Paul T. Kelly

Position:

Principal Engineer - Global Hazardous Locations

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**UL International Demko A/S**  
Borupvang 5A,  
DK-2750 Ballerup  
Denmark





# IECEx Certificate of Conformity

Certificate No: IECEx ULD 14.0005U Issue No: 2  
Date of Issue: 2016-11-22 Page 2 of 4  
Manufacturer: **Weidmüller Interface GmbH & Co. KG**  
Klingenbergstrasse 16  
32758 Detmold  
**Germany**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0  
**IEC 60079-7 : 2006-07** Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[DK/ULD/ExTR14.0004/02](#)

Quality Assessment Report:

[NL/DEK/QAR12.0052/03](#)



# IECEx Certificate of Conformity

Certificate No: IECEx ULD 14.0005U

Issue No: 2

Date of Issue: 2016-11-22

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

Description of Component: Feed through terminal blocks type WDU and protective conductor terminal blocks type WPE are for the connection of copper conductors in enclosures. The type of protection is increased safety, "e", insulating parts made of Wellamid, with optional accessories, type WQV screw in cross-connectors, type ZQV plug-in cross-connectors, type LS2.8 shield bus, type WEW end brackets, type WTW partitions and type WAP end plates for fixing on mounting rails.

See Annex for additional details.

Schedule of limitations:

Please see Annex.

**CONDITIONS OF CERTIFICATION: NO**



# IECEx Certificate of Conformity

Certificate No: IECEx ULD 14.0005U

Issue No: 2

Date of Issue: 2016-11-22

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Issue 1: New models of WDU, WPE, ZQV and WQV added: Models WDU 1.5/R3.5, WDU 1.5/ZZ, WDU 2.5/1.5/ZR, WDU 2.5/TC TYP B, WDU 2.5/TC TYP E, WDU 2.5/TC TYP J, WDU 2.5/TC TYP K, WDU 2.5/TC TYP N, WDU 2.5/TC TYP SR, WDU 2.5/TC TYP T, WDU 2.5N, WDU 4 SL, WDU 4 SL/EN, WDU 4/ZR, WDU 4/ZZ, WDU 4N, WDU 6 SL, WDU 6 SL/EN, WDU 10 SL, WDU 10 SL/EN, WDU 70N/35, WDU 70N/95N, WDU 95N/120N, WDU 120/150, WPE 1.5/ZZ, WPE 2.5/1.5/ZR, WPE 2.5N, WPE 4/ZR, WPE 4/ZZ, WPE 4N, WPE 70/95, WPE 70N/35, WPE 95N/120N, WPE 120/150, ZQV 1.5/3.5/2, WQV 70N/2, WQV 95/120/2 and WQV 70/95/2WQV/120/2. Voltage levels for WDU 6 and WDU 10 have been raised to 690V .

Issue 2: Alternate construction to multiple models.

## Annex:

[Annex to IECEx ULD 14.0005U.pdf](#)

**Annex to IECEx ULD 14.0005U Issue No.:2**  
**Applicant: Weidmüller Interface GmbH & Co. KG**

TYPE	Rated (V)	Rated (A)	Resistance (uΩ)	Strip length	Solid wire size (mm <sup>2</sup> )	Stranded wire size (mm <sup>2</sup> )	Flexible wire size (mm <sup>2</sup> )	2 wires in one terminal (mm <sup>2</sup> )
WDU 1.5/R3.5	275	15	430	7	0,14-1,5	0,14-1,5	0,14-1,5	0,5-0,75
WDU 1.5/ZZ	550	17,5	740	7	0,14-2,5	0,14-2,5	0,13-1,5	0,5 -1,0
WDU 2.5N	440	24	430	10	0,14-4,0	0,14-4,0	0,5-2,5	0,5-1,5
WDU 2.5/1.5/ZR	550	20	720	10	See NTI	See NTI	See NTI	See NTI
WDU2.5	690	24	369	10	0,14-4,0	0,14-4,0	0,14-4,0	0,5-1,5
WDU 2.5/TC B	55	8	3300	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC E	55	8	8650	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC J	55	8	5808	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC K	55	8	6705	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC N	55	8	9104	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC SR	55	8	2055	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC T	55	8	4611	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 4	690	32	298	10	0,14-6,0	0,14-6,0	0,14-6,0	0,5-2,5
WDU 4 N	352	31	270	11	0,13-6,0	0,13-6,0	0,13-4,0	0,5-1,5
WDU 4/ZR	690	31	440	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4/ZZ	690	29,5	560	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4 SL	440	32,0	300	13	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4 SL/EN	690	32,0	300	13	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 6	690	41	180	12	0,14-10,0	0,14-10,0	0,14-10,0	0,5-2,5
WDU 6 SL	275	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5
WDU 6 SL/EN TS 32	440	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5

**Annex to IECEx ULD 14.0005U Issue No.:2**  
**Applicant: Weidmüller Interface GmbH & Co. KG**

TYPE	Rated (V)	Rated (A)	Resistance (uΩ)	Strip length	Solid wire size (mm <sup>2</sup> )	Stranded wire size (mm <sup>2</sup> )	Flexible wire size (mm <sup>2</sup> )	2 wires in one terminal (mm <sup>2</sup> )
WDU 6 SL/EN TS 35	690	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5
WDU 10	690	57	152	12	1,31-16,0	1,31-16,0	1,31-16,0	0,5-6,0
WDU 10 SL /EN TS 32	550	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 10 SL /EN TS 35	690	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 10 SL	352	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 16	690	76	161	16	1,5-16,0	1,5-25,0	1,5-25,0	1,5-4,0
WDU 35	690	115	145	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-16,0
WDU 35N	352	110	122	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-6,0
WDU 50N	690	126	151	24	5,26-16,0	5,26-70,0	5,26-50,0	6,0-16,0
WDU 70N/35	690	184	142	22	10-16	10-95	10-70	10-25
WDU 70N/95	1100	218	53	30	16	16-120	16-95	16-35
WDU 95N/120N	880	221	129	27	16	16-150	16-120	10-35
WDU 120/150	1100	265	44	35	16	35-150	35-150	35-70
WPE 1.5/R3.5	N/A	N/A	1150	7	0,14-1,5	0,14-1,5	0,14-1,5	0,5-0,75
WPE1.5/ZZ	N/A	N/A		7	0,14-2,5	0,14-2,5	0,13-1,5	0,5 -1,0
WPE 2.5/1.5/ZR	N/A	N/A	660	10	See NTI	See NTI	See NTI	See NTI
WPE 2.5	N/A	N/A	833	10	0,14-4,0	0,14-4,0	0,14-4,0	0,5-1,5
WPE 2.5N	N/A	N/A	380	10	0,14-4,0	0,14-4,0	0,5-4,0	0,5-1,5
WPE 4	N/A	N/A	643	10	0,14-6,0	0,14-6,0	0,14-6,0	0,5-2,5

**Annex to IECEx ULD 14.0005U Issue No.:2**  
**Applicant: Weidmüller Interface GmbH & Co. KG**

TYPE	Rated (V)	Rated (A)	Resistance (uΩ)	Strip length	Solid wire size (mm <sup>2</sup> )	Stranded wire size (mm <sup>2</sup> )	Flexible wire size (mm <sup>2</sup> )	2 wires in one terminal (mm <sup>2</sup> )
WPE 4/ZZ	N/A	N/A	584	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WPE 4/ZR	N/A	N/A	570	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WPE 4N	N/A	N/A	740	11	0,13-6,0	0,13-6,0	0,13-4,0	0,13-1,5
WPE 6	N/A	N/A	256	12	0,14-10,0	0,14-10,0	0,14-10,0	0,5-2,5
WPE 10	N/A	N/A	221	12	1,31-16,0	1,31-16,0	1,31-16,0	0,5-6,0
WPE 16	N/A	N/A	178	16	1,5-16,0	1,5-25,0	1,5-25,0	1,5-4,0
WPE 35	N/A	N/A	173	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-16,0
WPE 35N	N/A	N/A	147	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-6,0
WPE 50N	N/A	N/A	189	24	5,26-16,0	5,26-70,0	5,26-50,0	6,0-16
WPE 70/95	N/A	N/A	76	30	16	16-120	16-120	16-35
WPE 70N/35	N/A	N/A	156	22	10-16	10-95	10-70	10-25
WPE 95N/120	N/A	N/A	126	27	16	16-150	16-120	10-35
WPE 120/150	N/A	N/A	67	35	35	35-150	35-150	35-70
WAP 2.5-10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WAP 16+35WTW 2.5-10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WEW 35/1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WEW 35/2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WTW EN	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
LS 2.8	See NTI	N/A	N/A	N/A	N/A	N/A	N/A	N/A
ZQV 1.5N/R3.5	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A

**Annex to IECEx ULD 14.0005U Issue No.:2**  
**Applicant: Weidmüller Interface GmbH & Co. KG**

TYPE	New (N) or original (O)	Rated (V)	Rated (A)	Resistance (uΩ)	Strip length	Solid wire size (mm <sup>2</sup> )	Stranded wire size (mm <sup>2</sup> )	Flexible wire size (mm <sup>2</sup> )	2 wires in one terminal (mm <sup>2</sup> )
ZQV 2.5N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
ZQV 4N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 2.5	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 4	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 6	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 10	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 16	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 35	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 35N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 50N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 70/95/2	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 70	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 95/120/2	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 120/2	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A



**Schedule of Limitations:**

The feed through and protective conductor terminal blocks are suitable for use in enclosures in atmospheres with flammable gases and combustible dust. For flammable gases these enclosures must satisfy the requirements according to IEC 60079-0 and 60079-7. For combustible dust these enclosures must satisfy the requirements according to IEC 60079-31.

The terminal blocks shall be placed inside a suitable IECEx certified IP54 enclosure for gas atmosphere. For dust atmosphere the terminal blocks shall be mounted inside a suitable IECEx certified 't' enclosure (IEC60079-31).

The enclosure shall be constructed to block all sun and UV light from affecting the terminal blocks.

Under normal operating conditions the temperature rise of the terminal blocks is max 40 K, measured with the max permitted rated current. Due to the above mentioned the terminal blocks may be used in apparatus of temperature classes T6...T1as long as the terminal block ambient temperature range is not exceeded as shown below. No part of terminal block must exceed 110 °C under any condition.

T6 (- 60°C ≤ Tamb ≤ +40 °C)

T5 (- 60°C ≤ Tamb ≤ +55 °C)

T4 (- 60°C ≤ Tamb ≤ +70 °C)

When using the types WDU and WPE with other terminal blocks series or sizes or accessories, the requirements for clearance and creepage distances according to table 1 of EN 60079-7 must be observed. Regarding the use of covers, cross-connectors and end brackets the instructions of the manufacturer must be followed.

For terminal jumper accessories current ratings and the resistances across the terminals please refer to the table under "types & electrical rating" above. Details on creepage and clearance values and the required torque values are in the respective "Notice to installers".

The terminal can be used with either one or two wires into either side of the terminal. When two wires are used they must be of the same type, and of equal sizes. No other wire sizes or types than the ones specified in instructions must be used. The terminal blocks must either be mounted next to another block of the same type and size or with an end plate.

If smaller conductor cross sections than the rated conductor cross sections are used, then the corresponding lower current shall be stated in the Certificate of the complete apparatus

Unused terminals shall be tightened.